

STATE OF MAINE DEPARTMENT OF TRANSPORTATION 16 STATE HOUSE STATION AUGUSTA, MAINE 04333-0016

DAVID A. COLE

May 14, 2004 Subject: Brewer Project No. NH-1139(800)E PIN 11398.00 Bid Amendment No. 1

Dear Sir/Ms.:

Please make the following changes in pen and ink to your bid package:

On the "Construction Notes" add the following Item:

Item 304.103 AGGR SUBB CRS-GRAVEL-TRUCK MS

This item is used to rebuild sidewalks as directed by Resident.

On the "Construction Notes" page 9 of 9 <u>Item 631.12- All purpose Exc.</u> (<u>Including Operator</u>), delete the entire sentence below this Item, and replace with:

"This item will be used to cut through the foam asphalt layer so that the Contractor will be able to access manholes, water shutoffs, and catch basins to raise as directed by the Resident."

On the "General Notes" page 3 of 3, add the following note number 37:

37. Flowable fill will be used to replace foam asphalt around manholes, water shutoffs and catch basins after adjusting them to finish grade. Payment shall be incidental to the appropriate adjust items.

Consider these changes prior to submitting your bid on May 19, 2004.

Sincerely.

Scott Bickford

Contracts & Specifications Engineer

